

A NOVEL TECHNIQUE ON LOADING BALANCE OF DISTRIBUTION FEEDERS WITH LOOP POWER CONTROLLERS CONSIDERING PHOTOVOLTAIC GENERATION

S.RADHA KRISHNA REDDY¹ ANWARUNNISA BEGUM² G.R.SHALINI³ Dr.JBV SUBRAHMANYAM⁴

Abstract— For the operation of distribution systems, loading balance of distribution feeders is important for reducing power loss and mitigating power flow overloading. In this paper, a loop power controller (LPC) is applied for the control of real power and reactive power flows by adjusting voltage ratio and phase shift so that the loading balance of distribution feeders can be obtained. To incorporate photovoltaic (PV) power generation in feeder loading balance, a Taipower distribution feeder with large PV installation is selected for computer simulation. Daily loading unbalance is determined by analyzing PV power generation recorded by the SCADA system and by constructing daily power load profiles based on distribution automation system (DAS) data. The load transfer required to achieve loading balance and the line impedance of distribution feeders are used to derive the voltage ratio and phase shift of the LPC. Computer simulations indicated that loading balance can be achieved in distribution feeders with large PV system installation by using loop power controllers according to the variation of solar energy and power loading of study feeders. The system power loss reduction resulting from feeder loading balance by LPC is also investigated in this paper.

Index Terms— Distribution automation system, loop power controller, photovoltaic.

INTRODUCTION

RENEWABLE energy resources such as wind and solar energy are increasingly integrated in power system planning and operation to achieve CO₂ emission reductions and to reduce consumption of fossil fuels by conventional thermal power generation. Penetration of wind power generation and PV power generation into distribution systems is expected to increase dramatically, which raises concerns about system impact by the intermittent power generation of DG [1]–[3]. Compared to large-scale wind power and conventional bulk generation, the generation cost of a PV system is relatively higher.

However, many countries offer significant financial subsidies to encourage customers to install PV systems. To achieve the goal of 1000 MW PV installed capacity by 2025, the Taiwan government has launched a promotion program to subsidize 50% of the PV installation cost and has increased the selling price of PV generation to 40¢/kWh [4].

It is critical for distribution systems to achieve loading balance of main transformers and feeders to prevent the system overloading problem during the summer peak period due to the usage of air conditioners. Loading balance is also important for both schedule outages and service restoration after fault isolation to perform load transfer between distribution feeders. To achieve better distribution system planning, loading balance is designed by the optimal reconfiguration of distribution networks so that system load demand can be evenly allocated among feeders and main transformers in substations. For distribution system operation, the loading balance is obtained by changing the open/closed status of line switches along distribution feeders so that partial loading of heavily loaded feeders/transformers can be transferred to relatively lightly loaded feeders/transformers with the adjustment of service zones.

However, feeder loading varies from time to time, which will make it very difficult to obtain the desired load balance with the network configuration in the system planning stage. Further, with more and more renewable distributed generation such as wind power and PV power being installed in distribution feeders, loading balance of distribution systems becomes more of a challenge due to the injection of intermittent power generation. Applying power electronics based flexible AC transmission system (FACTS) has been proven highly effective for controlling the load transfer between feeders to achieve loading balance [5].

Considerable efforts have been proposed in the previous works to solve the loading balance of distribution systems. The distribution static compensator (DSTATCOM) was considered for compensation of loading unbalance caused by stochastic load demand in distribution systems [6]. The

control algorithm for static var compensation (SVC) has been developed for loading balance at any given power factor [7]. Fuzzy multiobjective and Tabu search have been used to optimize the on/off patterns of tie switches and sectionalizing switches to achieve feeder loading balance in distribution systems with distributed generators [8]. A heuristic-expert system approach for network reconfiguration to enhance current balance among distribution feeders was presented by Reddy and Sydulu [9]. A Petri-Net algorithm has also been proposed for loading balance of distribution systems with open loop configuration by identifying open-tie switches [10].

For the distribution system with large capacity of PV installation, the feeder loading will be varied dramatically because the power injection by PV generation is varied with the intensity of solar radiation. The load transfer between controller (LPC) [12], [13] to replace the conventional open-tie switch so that loading balance of distribution feeders can be obtained by power flow control in a more active manner. A transformerless converter with snubber-less insulated gate bipolar transistor (IGBT) is applied to the proposed LPC using an active-gate-control (AGC) scheme. The AGC scheme can balance the collector voltage of IGBTs connected in series and allow the converter to connect directly to distribution feeders with a high enough AC voltage output [14]. Additionally, LPC can reduce the voltage fluctuation and system power loss by enhancing reactive power compensation. In this paper, the three-phase balanced flow condition is assumed for both distribution feeders to perform the load transfer by LPC.

The design of the LPC control strategy must consider intermittent power injection by PV generation and varying feeder loading so that the loading unbalance and system power loss can be minimized in each study hour. This paper is organized as follows. First, Section II introduces the distribution automation system with a loop power controller. Section III presents the feeder loading balance simulation and LPC control algorithm. In Section IV, the impact of the PV system on feeder loading balance and loss reduction of the distribution system is investigated. Finally, Section V gives conclusions.

II. DISTRIBUTION AUTOMATION SYSTEM WITH LOOP POWER CONTROLLER

To enhance reliability and operation efficiency of distribution systems, the fully integrated distribution automation system (DAS) in Fig 1 has been implemented by Taiwan Power Company (Taipower). The DAS consists of a master station (MS) with application software, remote terminal units (RTUs) in the substations, feeder terminal units (FTUs), and automatic line switches along the primary feeders [15].

feeders with an open-tie switch must be adaptively adjusted according to PV power generation. Due to the intermittent power generation by PV systems, it becomes very difficult to achieve loading balance with conventional network reconfiguration methods by changing the status of line switches. With the advancement of power electronics, the back-to-back (BTB) converters can be applied to replace the open-tie switch for better control of real power and reactive power load transfer by changing the voltage ratio and phase shift between two feeders according to the power unbalance at any time instant [11]. For the distribution system with high penetration of renewable energy sources, voltage profiles and loading balance have to be enhanced by improving the power exchange capability between feeders. This study propose a loop power

The distribution feeders from substations are connected as the open loop configuration with one of the automatic line switches being selected as the open-tie switch. To achieve loading balance of distribution feeders for normal operation with variation of feeder loading, the non-interruptible load transfer is executed

by closing the open-tie switch and opening one of the normal close switches. When a fault contingency occurs, the feeder circuit breaker trips, and the over-current fault flags of all upstream FTUs are set due to the large fault current flows. After the MS retrieves all fault flags, the fault location can therefore be determined according to the combination of fault flags and the network topology. The MS then sends the command to open all line switches around the faulted section to complete the fault isolation and followed by reclosing the feeder circuit breaker to restore power service to upstream customers. After verifying the reserve capacity of the supporting feeder, the open-tie switch is closed to fulfill the service restoration of downstream customers [16].

Although the DAS has been applied for fault restoration effectively in Taipower, the loading balance is difficult to be performed for distribution system with large DG facility because too frequently the switching operation is required to accommodate the dramatic fluctuation of DG generation.

To solve the problem, Fig. 1 shows how the proposed LPC is applied to replace the open-tie switch by achieving adaptive power flow control for load transfer. The distribution feeder-pair with LPC provides the following advantages: 1) improved controllability and operational flexibility of the distribution system; 2) mitigation of voltage fluctuation with fast reactive power compensation; 3) control of the real and reactive power flow; 4) reduced power system loss with improved loading balance of the distribution system; and 5) enhanced system robustness for integration with more renewable energy [11].




Fig. 1. Distribution automation system with a loop power controller.

III. CONTROL MODEL OF LOOP POWER CONTROLLER

To derive the voltage ratio and phase shift of LPC for the control of load transfer, the equivalent circuit model of LPC is proposed by considering the branch impedances of distribution feeders for the simulation of feeder loading balance. Fig. 2 shows the overall process to derive the LPC control algorithm to enhance loading balance of distribution feeders.

A. Simulation of Feeder Loading Balance

In this study, the LPC is considered as the combination of tap changer and phase shifter with a circuit model as shown in Fig. 3. By adjusting the voltage ratio and phase shift between both sides of the LPC according to the branch impedance and loading unbalance of distribution feeders, the real and reactive power flows through the LPC can be controlled to achieve the loading balance.




Fig. 4. Modified equivalent circuit model of LPC.




Fig.3.Circuit modal of PL




Fig. 2. Flowchart of LPC control algorithm.

The equivalent injection currents are solved as

$$dI_s' = -(n^2 - 1)\bar{y}\bar{V}_s - (1 - n)\bar{y}\bar{V}_r \quad (4)$$

$$dI_r' = -(1 - n)\bar{y}\bar{V}_s \quad (5)$$

To derive the injection current due to the change of phase shift by LPC, the node currents are represented by assuming a fixed voltage ratio of 1.0 as follows:

$$I_s = \bar{y}\bar{V}_s - \bar{y}e^{-j\phi}\bar{V}_r = (1 - e^{-j\phi})\bar{y}\bar{V}_r + \bar{y}(\bar{V}_s - \bar{V}_r) \quad (6)$$

$$I_r = (1 - e^{-j\phi})\bar{y}\bar{V}_s + \bar{y}(\bar{V}_r - \bar{V}_s) \quad (7)$$

The equivalent injection currents are solved as:

$$dI_s'' = -(1 - e^{-j\phi})\bar{y}\bar{V}_r \quad (8) \text{ \& } (9)$$

$$dI_r'' = -(1 - e^{-j\phi})\bar{y}\bar{V}_s$$

The equivalent circuit model can be represented as an ideal transformer with turn ratio of 1: $ne^{j\phi}$ and a series admittance y .

The mathematical model of LPC can be illustrated in (1) to represent the relationship between the node injection currents and voltages:

$$\begin{bmatrix} \bar{I}_s \\ \bar{I}_r \end{bmatrix} = \begin{bmatrix} n^2\bar{y} & -n^2\bar{y} \\ -n\bar{y} & \bar{y} \end{bmatrix} \begin{bmatrix} \bar{V}_s \\ \bar{V}_r \end{bmatrix} \quad (1)$$

Where $\bar{n} = ne^{j\phi}$.

To simplify the process to determine the voltage ratio and phase shift of LPC, this paper proposes a modified π equivalent circuit with dependent current source $d\bar{I}_s$ and $d\bar{I}_r$ as shown in Fig. 4. Here, the dependent current sources are revised according to the adjustments of turn ratio and phase shift during the iteration process. To derive the injection currents due to the change of voltage ratio by LPC, the node currents are represented by assuming zero phase shift as follows:

$$\begin{aligned} I_s &= n^2\bar{y}\bar{V}_s - n\bar{y}\bar{V}_r \\ &= (n^2 - 1)\bar{y}\bar{V}_s + (1 - n)\bar{y}\bar{V}_r + \bar{y}(\bar{V}_s - \bar{V}_r) \end{aligned} \quad (2)$$

$$\begin{aligned} I_r &= -n\bar{y}\bar{V}_s + \bar{y}\bar{V}_r \\ &= (1 - n)\bar{y}\bar{V}_s + \bar{y}(\bar{V}_r - \bar{V}_s) \end{aligned} \quad (3)$$

Therefore, the equivalent currents due to the change of both voltage ratio and phase shift by LPC in Fig. 4 are determined as follows:

$$dI_s = dI_s' + dI_s'' \quad (10)$$

$$dI_r = dI_r' + dI_r'' \quad (11)$$

$$\begin{bmatrix} d\bar{I}_s \\ d\bar{I}_r \end{bmatrix} = \begin{bmatrix} (1 - n^2)\bar{y} & (n + e^{-j\phi} - 2)\bar{y} \\ (n - 1)\bar{y} & (n + e^{-j\phi} - 2)\bar{y} \end{bmatrix} \begin{bmatrix} \bar{V}_s \\ \bar{V}_r \end{bmatrix} \quad (12)$$

By this way, the network impedance matrix remains unchanged during the iteration process to solve the voltage ration and phase shift of LPC.

B. LPC Control Algorithm

To illustrate the proposed control algorithm for LPC to achieve feeder loading balance, consider the two sample radial feeders connected with an LPC in Fig. 5. The desired real and reactive power flows through the LPC for feeder loading balance are defined as

$$P_{LPC} = \frac{P_1 - P_2}{2} \tag{13}$$

$$Q_{LPC} = \frac{Q_1 - Q_2}{2}$$

If the branch impedances of Feeder 1 and Feeder 2 are $(R_1 X_1)$ And $(R_2 X_2)$, respectively, the total impedance of

two feeders is defined as

$$\begin{aligned} R_t &= R_1 + R_2 \\ X_t &= X_1 + X_2 \end{aligned} \tag{14}$$




Fig. 5. Incremental circuit model of distribution feeders with LPC.




Fig. 6. Taipower distribution feeders for computer simulation.

In order to perform the LPC control strategy to have the proper load transfer between both feeders for loading balance, the terminal voltage V_{L1} at the primary side of LPC is assumed to have a fixed value of 1.0. The terminal voltage at the secondary side of LPC is derived in (15):

$$V_{L2}' = \sqrt{(1 + P_{LPC}R_t + Q_{LPC}X_t)^2 + (P_{LPC}X_t - Q_{LPC}R_t)^2}$$

$$\Delta V = |\bar{V}_{L2}| - 1.0 \tag{16}$$

$$\Delta \phi = \tan^{-1} \frac{P_{LPC}X_t - Q_{LPC}R_t}{1 + P_{LPC}R_t - Q_{LPC}X_t} \tag{17}$$

The incremental terminal voltage and phase shift are therefore calculated as follows in (16) & (17).

IV. CASE STUDY OF TAIPOWER DISTRIBUTION SYSTEM

To demonstrate the effectiveness of the proposed LPC for loading balance of distribution feeders with PV facility, a Taipower distribution system serving Kaohsiung Stadium for 2009 World Games in Taiwan has been selected for computer Simulation as shown in Fig. 6. A large-scale PV system with 8844 pieces of solar panels has been installed on the roof with total capacity of 1027 kWp. Feeder MF65 is supplied by Bei-Ying substation to serve Kaohsiung Stadium and other low-voltage customers. The feeder is connected to Feeder MU67 with an open line switch so that the load transfer can be executed for service restoration during fault emergency. With such a large PV system being installed, it is expected that total annual PV electricity energy of 1.37 GWh can be generated [17]. Fig. 7 shows the one-line diagram of the power system in the stadium. There are 179 units of DC/AC inverters which are used to convert the solar panel generation to 380 Vac. Besides serving the local loads in the stadium, the surplus power generated by the PV system is also sold to Taipower system.




Fig. 7. One-line diagram of Kaohsiung Main Stadium




Fig. 8. Actual PV power generation of Kaohsiung Stadium (June 30, 2009).

The daily power generation of the study PV system has been recorded by the SCADA system as shown in Fig. 8. It is found that the PV power generation is increased with solar irradiation. The maximum power generation was 768 kWh at 12 PM, and the total harvesting energy of 6702 kWh has been obtained for June 30, 2009.

Fig. 9 shows the daily profiles of real and reactive power loading of Feeders MF65 and MU67 without considering the power injection by the PV system. The peak loading of Feeder MF65 was 3724 kW/1232 kVAR at 8 PM and the peak loading of Feeder MU67 was 4483 kW/1485 kVAR at 2 PM. Feeder MF65 serves the residential area with customers consuming most of the power demand during night time period when people stay at home with heavy air conditioner loading. Feeder MU67, however, serves the commercial area with customers consuming most of power demand during daytime business hours.

Fig. 10 shows the reduction of real power loading of Feeder MF65 during daytime period after integrating PV power generation in the distribution system.

A. Loading Balance of Distribution Feeder by a Loop Power Controller

With the variation of customer loading profiles and the intermittent generation of PV systems, an adaptive LPC control algorithm is derived to adjust the voltage ratio and phase shift between both feeders according to the feeder loading and PV generation for each study hour. To illustrate the effectiveness of LPC for system loading balance, an LPC is assumed to be installed to replace the open-tie switch between Feeders MF65




Fig. 10. Power profiles of Feeder MF65 and MU67 (with PV system).




Fig. 11. Loading balance of both feeders with the control of LPC (w/o PV system).

and MU67 in Fig. 6. After executing the loading balance by LPC for the distribution system without considering the PV system of Kaohsiung Stadium, Fig. 11 shows the real power and reactive power profiles of both feeders. By comparing to Fig. 9, it is found that the loading balance of the study system is significantly improved by LPC to achieve proper control of power transfer between both feeders. The differences of real power and reactive power loadings between Feeders MF65 and MU67 at 3 PM have been reduced from 1864 kW/1715 kVAR to 170 kW/71 kVAR after implementing LPC for power flow control.




Fig. 9. Power profiles of Feeder MF65 and MU67 (without PV system).




Fig. 12. Voltage ratio and phase shift for the power transfer by LPC (without the PV system).

Fig. 12 shows the corresponding voltage ratio and phase shift for each study hour, which are derived in (16) and (17) for LPC control to achieve the load transfer between both feeders. At 3

PM, a phase shift of -0.1° is applied for real power transfer of 1012 kW from MU67 to MF65 while the voltage ratio of 0.013 p.u. is applied for reactive power transfer of 890 kVAR from MU67 to MF65. On the other hand, a phase shift of 0.27° is used for real power transfer of 450 kW from MF65 to MU67 at 6 AM, and the voltage ratio of 0.001 p.u. is applied for reactive power transfer of 190 kVAR from MU67 to MF65.

When the PV system of Kaohsiung Stadium is integrated in the distribution system, the power loading of Feeder MF65 is reduced as PV power generation is injected into the system during the daytime period. To achieve the loading balance, the voltage ratio and phase shift by LPC have to be revised as shown in Fig. 13 according to the variation of PV power generation. By comparing to Fig. 12, the voltage ratio of LPC remains the same because the PV system does not generate reactive power. However, the phase shift of LPC required for real power balancing is increased during the daytime period when the real power generated by the PV system is injected. For instance, a larger phase shift of -0.3° is applied for real power transfer of 897 kW from MU67 to MF65 at 3 PM. With the control of LPC, the loading balance of test feeders by including the PV power generation has been obtained as shown in Fig. 14. By comparing to Fig. 10, the mismatches of real power and reactive power loadings between Feeder MF 65 and Feeder MU 67 at 3 PM are reduced from 2574 kW/1727 kVAR to 191kW/79 kVAR after loading balance.

B. Distribution Feeder Loss Analysis

To investigate the effectiveness of LPC for the reduction of system power loss by loading balance, a three-phase power flow analysis is performed for both feeders MF65 and MU67 by considering the daily feeder power loading profiles before and after loading balance. Also, the loss incurred in LPC is assumed to be 1% of the power transfer by the LPC which has been included in the system loss analysis for each study hour. For the test distribution system with PV system, Fig. 15 shows the system power loss as percentages of feeder loading. Without applying the LPC for loading balance, the feeder power loss varies from 1.2% of the feeder loading during the light load period to 3.3% during the peak load period. The power loss over the daily period is reduced from 3457 kWh (2.8%) to 2970 kWh (2.3%) after loading balance by LPC. The system power loss reduction has therefore been obtained after implementing the LPC for loading balance




Fig. 13. Voltage ratio and phase shift with the control of LPC (with PV system).




Fig. 14. Loading balance of both feeders with the control of LPC (with PV system).




Fig. 15. Percentage of system power loss before and after applying LPC for loading balance (with PV system).

V. CONCLUSIONS

This study evaluates a power electronics-based loop power controller to replace the open-tie switch for the control of real power and reactive power transfer between distribution feeders to achieve loading balance of distribution system. The voltage ratio and phase shift adjusted by LPC are derived according to mismatches of real power and reactive power loadings between test feeders for each study hour. To demonstrate the effectiveness of LPC for the enhancement of loading balance, a Taipower distribution system consisting of two feeders with a large-scale PV system has been selected for computer simulation. The power loadings of the study feeders and the PV power generation have been recorded. By applying the control algorithm of LPC to adjust the voltage ratio and phase shift between both feeders, the proper amount of real power and reactive power can be transferred from the heavily loading feeder to the lightly loading feeder for each study hour. According to the computer simulation, it is concluded that the loading balance of distribution systems with intermittent PV power generation can be obtained effectively by the implementation of LPC to achieve adaptive control of load transfer between distribution feeders. The power loss reduction of test feeders after loading balance by LPC has also been derived in this paper.

REFERENCES

- [1] J. Bebic, R. Walling, K. O'Brien, and B. Kroposki, "The sun also rises," *IEEE Power Energy Mag.*, vol. 7, no. 3, pp. 45–54, May./Jun. 2009.
- [2] T. Key, "Finding a bright spot," *IEEE Power Energy Mag.*, vol. 7, no. 3, pp. 34–44, May./Jun. 2009.
- [3] Y. Zhu and K. Tomsovic, "Adaptive power flow method for distribution systems with dispersed generation," *IEEE Trans. Power Del.*, vol. 17, no. 3, pp. 822–827, Jul. 2002.
- [4] 2008 Report of Long-Term Load Forecasting and Energy Development, Bureau of Energy, Ministry of Economic Affairs, Taiwan, Dec. 2008.
- [5] N. Okada, "A method to determine the distributed control setting of looping devices for active distribution systems," in *Proc. 2009 IEEE Bucharest PowerTech (POWERTECH)*, Bucharest, Romania, Jun. 2009, pp. 1–6.
- [6] B. Singh and J. Solanki, "A comparison of control algorithms for DSTATCOM," *IEEE Trans. Ind. Electron.*, vol. 56, no. 7, pp. 2738–2745, Jul. 2009.
- [7] S. A. Farouji, E. Bakhshizadeh, R. Kazemzadeh, and R. Ghazi, "The static var compensator equations development for loading balance at

desired power factor based on load admittance parameters and instantaneous voltage and current values,” in *Proc. 2009 Int. Conf. Elect. Power Energy Conversion Syst.*, Sharjah, United Arab Emirates, Nov. 10–12, 2009, pp. 1–6.

[8] N. Rugthaicharoencheep and S. Sirisumrannukul, “Feeder reconfiguration with dispatchable distributed generators in distribution system by tabu search,” in *Proc. 2009 44th Int. Universities Power Eng. Conf. (UPEC 1009)*, Glasgow, U.K., Sep. 1–4, 2009, pp. 1–5.

[9] V. V. K. Reddy and M. Sydulu, “A heuristic-expert based approach for reconfiguration of distribution systems,” in *Proc. 2007 IEEE Power Eng. Soc. General Meeting*, Tampa, FL, Jun. 24–28, 2007, pp. 1–4.

[10] C. H. Lin, “Distribution network reconfiguration for loading balance with a coloured petri net algorithm,” *Proc. Inst. Elect. Eng., Gen., Transm., Distrib.*, vol. 150, no. 3, pp. 317–324, May 2003.

[11] N. Okada, M. Takasaki, H. Sakai, and S. Katoh, “Development of a 6.6 kv–1 MVA transformerless loop balance controller,” in *Proc. IEEE 38th Annu. Power Electron. Specialists Conf.*, Orlando, FL, Jun. 17–21, 2007, pp. 1087–1091.

[12] N. Okada, “Verification of control method for a loop distribution system using loop power flow controller,” in *Proc. 2006 IEEE PES Power Syst. Conf. Expo.*, Atlanta, GA, Oct./Nov. 2006, pp. 2116–2123.

[13] N. Okada, H. Kobayashi, K. Takigawa, M. Ichikawa, and K. Kurokawa, “Loop power flow control and voltage characteristics of distribution system for distributed generation including PV system,” in *Proc. 3rd World Conf. Photovoltaic Energy Conversion*, Osaka, Japan, May 12–16, 2003, pp. 2284–2287.

[14] N. Okada, M. Takasaki, J. Narushima, R. Miyagawa, and S. Katoh, “Series connection of snubberless igbts for 6.6 kv transformerless converters,” in *Proc. 2007 Power Conversion Conf.*, Nagoya, Japan, Apr. 2007.

[15] G. L. Ockwell, “Implementation of network reconfiguration for Taiwan power company,” in *Proc. 2003 IEEE Power Eng. Soc. General Meeting*, Toronto, ON, Canada, Jul. 2000

[16] C. S. Chen, C. H. Lin, and H. Y. Tsai, “A rule-based expert system with colored petri net models for distribution system service restoration,” *IEEE Trans. Power Syst.*, vol. 17, no. 4, pp. 1073–1080, Nov. 2002.

[17] TheWorld Games 2009 Kaohsiung, TheWorld Games 30+ Top Sports-High Spirits.

AUTHORS:



¹**S.RADHA KRISHNA REDDY** received the **B.Tech.** degree in **EEE** from MITS ENGG College, Madanapalle, Chittoor(Dt), Andhra Pradesh, India, from JNTU University and **M.Tech.** in **Power Electronics** from S.K. University in the year 2007. He has teaching experience of 06 years & Currently working as Associate Professor in Holy Mary Institute of Technology & Science, Bogaram, R.R. Dist, Hyderabad, Andhra Pradesh, India in the Dept. of Electrical & Electronics Engg. He published **09** research papers in reputed International Journals and **04** papers in International and National conferences. His Interest areas are Neural Networks, Power Electronics & Drives, FACTS, etc.



²**Anwarunnisa Begum** pursuing **M.Tech** in **ELECTRICAL POWER SYSTEMS** from HITS College of Engineering, Bogaram, keasara, R.R Dist. She completed **B.Tech in EEE** from Shadan women’s engineering college, affiliated to JNT UNIVERSITY. She has worked as an Assistant professor in shadan engineering college for 2 yrs. She worked as Asst.Professor in Islamia women’s engineering college for 1 year. She was the organizer of National level student technical symposium held at SHADAN ENGINEERING COLLEGE, hyderabad. Her areas of interest are Power Systems, Power Electronics and Drives and Facts.



⁴**Dr.JBV Subrahmanyam** is a Doctorate in Electrical Engineering from JNTU-Hyderabad, India, with two decades of rich experience in teaching, training, research, industry, projects and consultancy. He published 25 research papers in reputed international journals and 20 papers in international and national conferences. His research interest is in automation of power systems. He is an expert in condition monitoring of industrial equipment through modern diagnostic techniques.

He implemented the latest GPS and GIS technologies in many power utilities in India successfully. He executed many international and national level technical projects effectively funded by Power Finance Corporation, Ministry of Power, Government of India, APDRP, DRUM, USAID and DFID-UK.

