

## Loss Reduction in Radial Distribution Network by Optimal Placement of Type – I DG Using Modified Direct Search Algorithm

P. Anil Kumar<sup>1</sup>, B. Shankar Prasad<sup>2</sup>

PG Student, Dept. of EEE, AVANTHI'S St. Theresa Institute of Engineering & Technology, Garividi, Andhra Pradesh, India<sup>1</sup>

Associate Professor, HOD, Dept. of EEE, AVANTHIS'S St. Theresa Institute of Engineering & Technology, Garividi, Andhra Pradesh, India<sup>2</sup>

### ABSTRACT

In this paper, Direct Search Algorithm is implemented to determine the optimal sizes of Type – I Distributed Generators (DGs) and optimal locations such that maximum possible reduction in real power loss is obtained. Type – I DG injects both active and reactive powers. The algorithm searches for all possible locations in the system for a particular size of DG and places it at the bus which gives maximum reduction in active power loss. The optimal sizes of DGs are chosen to be standard sizes i.e., discrete sizes of DGs are considered. The algorithm is tested on 33 bus and 69 bus Radial Distribution Systems. The loss reduction obtained in this paper for the 33 bus and 69 bus test systems are highest compared to other techniques in the literature. Power factor of the DG is considered in this study is 0.85.

On 33 bus system, without placement of DGs the loss is 211 kW whereas after placement it is 15.50 kW. There is a reduction of 92.65% in the losses. Before placement of DGs, the power loss is 5.37% of the total power supplied by the slack bus. After optimal placement by the MODIFIED DSA algorithm, the active power loss is 0.415% of the total power supplied by the system. On 69 bus system, without placement of DGs the loss is 225 kW whereas after placement is 5.75 kW. There is a reduction of 97.44% in the losses. Before placement of DGs, the power loss is 5.58% of the total power supplied by the slack bus. After optimal placement by the MODIFIED DSA algorithm, the active power loss is 0.15% of the total power supplied by the system.

As the loss is less than 2%, the system is considered as Loss Less Distribution System. It is implemented using MATLAB/Simulink.

**Keywords:** Loss Less Distribution, Optimal DG Placement, Distribution Systems, Modified Direct Search Algorithm (MODIFIED DSA).

### I. INTRODUCTION

Optimal capacitor placement is implemented for improving the voltage profile and reducing the power loss. Optimal DG placement is implemented for reduction of active power loss and to improve the reliability of the system. Very few papers have addressed the concept of minimizing the active loss by placing both DGs and Capacitors at their optimal locations. This concept works well for the developing countries like India, where the 11KV rural distribution feeders are too long. The voltages at the far end of many such feeders are very low with very poor voltage regulation.

The computational methods used in the analysis and design of distribution systems are not as robust as they are in transmission systems. In particular, the design of compensation systems for radial distribution system has become very complex because, the system does not fit into the usual optimization methods used in transmission system. In this paper, only one phase of Direct Search Algorithm is used according to the requirement of

Type-1 DG. Capacitive compensation is not required in this case as reactive power is injected by DG itself. In the case of Type-2 and Type-3 DG, capacitive compensation is separately required. This algorithm is an extension of Direct Search Algorithm for Capacitive compensation proposed by M. Ramalinga Raju et. al.[1].

The technical merits of DG implementation include voltage support, energy-loss reduction, release of system capacity, and improve utility system reliability [2]. By supplying power during peak load periods DG can best serve as a price hedging mechanism. Numerous techniques are proposed so far to address the viability of DGs in power system. Besides, several optimization tools, including artificial intelligence techniques, such as genetic algorithm (GA), Tabu search, etc., are also proposed for achieving the optimal placement of DG. An optimization approach using GA for minimizing the cost of network investment and losses for a defined planning horizon is presented in [3]. The method for optimal placement of DG for minimizing real power

losses in power distribution system using GA is proposed in [4].

The gradient and second order methods to determine the optimal location for the minimization of losses is employed in [5]. An iterative method that provides an approximation for the optimal placement of DG for loss minimization is demonstrated in [6]. Analytical methods for determining optimal location of DG with the aim of minimizing power loss are proposed in [7]. Optimal placement of DG with Lagrangian based approach using traditional pool based Optimal Power Flow and voltage stability constrained Optimal Power Flow formulations is proposed in [8].

Carpinelli et al. implemented [9] non-linear programming technique for capacitor placement on three phase unbalanced system. Wang et al. implemented [10] integer programming technique, and Tabu search was used by Huang et al. [11] for optimal capacitor placement. Grainger implemented equal area criterion [12] and genetic algorithm applied to capacitor placement by Dlfanti [13] for determining optimal sizes of capacitors. Das applied Fuzzy- GA method for capacitor placement problem [14]. Sydulu and Reddy applied Index Vector to capacitor placement problem [15], Prakash and Sydulu applied particle swarm optimization for optimal capacitor placement problem [16]. Safigianni and Salis presented optimum VAr control of radial primary power distribution networks by shunt capacitor installation [17]. Das implemented genetic algorithm [18], Hsiao implemented Fuzzy-genetic algorithm for [19] for optimal capacitor placement problem. Huang applied immune multi objective algorithm for capacitor placement problem [20]. Kannana et al. applied Fuzzy-Differential Algorithm [21], Srinivasa Rao et al. applied plant growth algorithm for optimal capacitor placement problem [22].

DGs are considered as small power generators that complement central power stations by providing incremental capacity to power system. DGs may never replace the central power stations. However, penetration and viability of DG at a particular location is influenced by technical as well as economic factors.

The MODIFIED DSA algorithm implemented, with a possible expert interaction yields optimal locations with suitable sizes of DGs, results in minimum active power loss. The algorithm is implemented on 33 Bus and 69 Bus Standard Test Systems. 69 Bus data is available in [23]. Type -1 DG injects active power and reactive power into the system as mentioned in [24].

## II. THE MODIFIED DSA ALGORITHM

The DSA algorithm is slightly modified for Type-1 DG placement in radial distribution system with source bus as slack bus and all other load buses

as PQ buses. The algorithm implemented is described in following steps for deciding the optimal sizes of DGs and their locations (only load buses). The algorithm is presented in the following steps:

1. Calculate the total active power load in the system. To determine the optimal sizes of DGs, a number of options having group of various DG sizes are to be tried. A tolerance index is chosen. Losses under any option should be less than the tolerance index for convergence. All possible options may be enlisted.
2. Let a(t) be the number of DGs t<sup>th</sup> option, 't' ranging from 1 to d where 'd' is the total number of options. a(1) , the first option is with single DG, the P (active power) of which is nearest to the total KW load, placed at all load buses, in turn, and load flow study is conducted. The line losses are determined. If the lowest loss satisfies the tolerance criterion, the process can be terminated. The size and location of DG are considered as the optimal solution.
3. In one set of DGs a(t), the first DG is kept at all load buses in turn, and the location for which losses are the lowest is considered as the optimal location for that DG. Placing this DG at that load bus, the procedure is repeated for placing the second DG at all load buses in turn and deciding the optimal location for the second DG. This procedure is repeated for all DGs.
4. The options a(2) to a(d) are sequenced taking more and more number of DGs of smaller size such that the total DG capacity is nearest to the total KW of the system. System losses are found out for each combination and checked for tolerance. If the tolerance is acceptable, process can be terminated.

## III. RESULTS

The standard sizes of DGs, and their corresponding reactive power injections are presented in Table I at 0.85 power factor.

Table I : Different DGs considered for placement

S. No.	kW capacity	kVAr capacity
1	1000	619.74
2	500	309.87
3	300	185.92
4	200	123.94
5	100	61.97

The MODIFIED DSA Algorithm is implemented on 69 - Bus System. The total active and reactive power demand of the system is 3802.19 kW and 2694.60 kVAr respectively. Without placement of DGs the loss is 225 kW. After placing

Type-1 DGs the loss is 5.75 kW. There is a reduction of 97.44% in the losses. Before placement of DGs, the power loss is 5.58% of the total power supplied by the slack bus. After optimal placement by the MODIFIED DSA algorithm, the active power loss is 0.15% of the total power supplied by the system.

The MODIFIED DSA Algorithm is implemented on 33 - Bus System. The total active and reactive power demand of the system is 3715 kW and 2300 kVAr respectively. Without compensation, the losses are 211kW. After placing Type-1 DGs the loss is 15.50 kW. Before placement of DGs, the loss is 5.37% of the total power supplied by Slack Bus. After placement, the loss is 0.415% of the total power supplied by the slack bus.

The Table II shows the best combination of DGs with location for 69 bus system and fourth column shows active power loss after placing capacitors in turn. Fig. 1 shows the reduction in active power loss by optimal placement of DGs. X-axis shows the number of DG mentioned in the order of Table II.

The Table III shows the best combination of DGs with location for 33 bus system and fourth column shows active power loss after placing capacitors in turn. Fig. 2 shows the reduction in active power loss by optimal placement of DGs. X-axis shows the number of DG mentioned in the order of Table III.

Table- II: Type -1 DG placement on 69- bus system using Direct Search Algorithm

S. No	Active Power supplied by the DG (kW)	Reactive Power supplied by DG (kVAr)	Min Loss Location	Active power loss after placing the DGs in turn ( kW)
1	1000	619.74	61	64.80
2	1000	619.74	61	24.29
3	500	309.87	18	9.57
4	300	185.92	50	8.11
5	300	185.92	11	6.77
6	300	185.92	49	6.03
7	200	123.94	49	5.86
8	100	61.97	46	5.75




Fig. 1 Reduction in active power loss by Type-1 DG placement

Table- III: Type -1 DG placement on 33- bus system using Direct Search Algorithm

S. No	Active Power supplied by the DG (kW)	Reactive Power supplied by DG (kVAr)	Min Loss Location	Active power loss after placing the DGs in turn ( kW)
1	1000	619.74	30	93.79
2	1000	619.74	11	35.47
3	500	309.87	25	21.58
4	500	309.87	24	17.7
5	100	61.97	22	16.87
6	100	61.97	26	16.18
7	100	61.97	21	15.78
8	100	61.97	5	15.50




Fig. 2 Reduction in active power loss by Type-1 DG placement

#### IV. CONCLUSIONS

In this paper, Direct Search Algorithm is implemented to determine the optimal sizes of Distributed Generators (DGs) with their optimal locations in 33 Bus and 69 Bus Radial Distribution System so that maximum possible reduction in real power loss is obtained. The optimal sizes of Type -1 DGs are chosen to be standard sizes i.e., discrete sizes of DGs are considered.

On 33 bus system, without placement of DGs the loss is 211 kW whereas after placement it is 15.50 kW. There is a reduction of 92.65 in the losses. Before placement of DGs, the power loss is 5.37% of the total power supplied by the slack bus. After optimal placement by the MODIFIED DSA algorithm, the active power loss is 0.415% of the total power supplied by the system. On 69 bus system, without placement of DGs the loss is 225 kW whereas after placement it is 5.75 kW. There is a reduction of 97.44% in the losses. Before placement of DGs, the power loss is 5.58% of the total power supplied by the slack bus. After optimal placement by the MODIFIED DSA algorithm, the active power loss is 0.15% of the total power supplied by the system.

#### REFERENCES

[1] M. Ramalinga Raju, K. V. S. Ramachandra Murthy, K. Ravindra, Direct Search Algorithm for Capacitive Compensation in

- Radial Distribution systems, International Journal of Electrical Power and Energy Systems, Volume 42, March, 2012, Page: 24 – 30.
- [2] P.P. Barker, Determining the impact of distributed generation on power systems: Part 1 -radial distribution systems, in: Proceedings of IEEE Power Engineering Society Summer Meeting, 2000, pp. 1645–1656.
- [3] G. Celli, F. Pilo, Optimal distributed generation allocation in MV distribution networks, in: 22nd IEEE PES International Conference on Power Industry Computer Applications PICA 2001, Sydney, Australia, May 2001, pp. 81–86.
- [4] N. Mithulanathan, Than Oo, LeVan Phu, Distributed generator placement technique in power distribution system using genetic algorithm to reduce losses, *Thammasat Int. J. Sci. Tech.* 9 (September (3)) (2004) 56–62.
- [5] N.S. Rau, Y.H. Wan, Optimum location of resources in distributed planning, *IEEE Trans. Power Syst.* 9 (4) (1994) 2014–2020.
- [6] T. Griffin, K. Tomsovic, D. Secrest, A. Law, Placement of dispersed generations systems for reduced losses, in: Proceedings of the 33rd Hawaii International Conference on System Sciences, Hawaii, 2000.
- [7] C. Wang, M. Hashem Nehrir, Analytical approaches for optimal placement of distributed generation sources in power systems, *IEEE Trans. Power Syst.* 19; November (4); 2004; 2068–2076.
- [8] W. Rosehart, Optimal placement of distributed generation, in: Nowicki (Ed.), 14th PSCC, Sevilla, 24–28 June 2002.
- [9] Carpinelli G, Varilone P, Di Vito V, Abur A. Capacitor placement in three-phase distribution systems with nonlinear and unbalanced loads. *IEE Proc Generation Transmission Distribution* 2005;152(1):47–52.
- [10] Wang J, Chiang H, Nanminu K, Darling G. Capacitor placement and real time control in large-scale un-balanced distribution systems: Part I and II. *IEEE Trans Power Delivery* 1997;12:953–64.
- [11] Huang YC, Yang HT, Huang CL. Solving the capacitor placement problem in a radial distribution system using Tabu search application. *IEEE Trans Power System* 1996; 11:1868–73.
- [12] Grainger JJ, Lee SH. Optimum size and location of shunt capacitors for reduction of losses on distribution feeders. *IEEE Trans Power App System* 1981;100:1105–18.
- [13] Dlfanti M, Granelli GP, Maranninio P. Optimal capacitor placement using deterministic and genetic algorithm. *IEEE Trans Power System* 2000;15: 1041–6.
- [14] Das D. Optimal placement of capacitors in radial distribution system using Fuzzy-GA method. *J Electr Power Energy Syst* 2008;30: 361–7.
- [15] Sydulu M, Reddy VVK. Index and GA based optimal location and sizing of distribution system capacitors. In: Power engineering society general meeting, Tampa, FL; 2007. p. 1–4.
- [16] Prakash K, Sydulu M. Particle swarm optimization based capacitor placement on radial distribution systems. *Power Eng Soc Gen Meet* 2007: 1–5.
- [17] Safigianni AS, Salis GJ. Optimum VAR control of radial primary power distribution networks by shunt capacitor installation. *Electrical Power Energy System* 2001;23:389–401.
- [18] Das D. Reactive power compensation for radial distribution networks using genetic algorithm. *Electr Power Energy System* 2002;24:573–81.
- [19] Hsiao Ying-Tung, Chen Chia-Hong, Chien Cheng-Chih. Optimal capacitor placement in distribution systems using a combination Fuzzy-GA method. *Electr Power Energy Syst* 2004;26(7):501–8.
- [20] Huang Tsong-Liang, Hsiao Ying-Tung, Chang Chih-Han, Jiang Joe-Air. Optimal placement of capacitors in distribution systems using an immune multi objective algorithm. *Electrical Power Energy Syst* 2008;30:184–92.
- [21] Kannana SM, Renugab P, Kalyania S, Muthukumarana E. Optimal capacitor placement and sizing using Fuzzy-DE and Fuzzy-MAPSO methods. *Appl Soft Comput* 2011.
- [22] Srinivasa Rao R, Narasimham SVL, Ramalingaraju M. Optimal capacitor placement in a radial distribution system using plant growth simulation algorithm. *Electr Power Energy Syst* 2011;33:1133–9.
- [23] D. Das, Optimal placement of capacitors in radial distribution system using a Fuzzy-GA method, *International Journal of Electrical Power and Energy Systems* 30 (2008) 361–367
- [24] Duong Quoc Hung, Nadarajah Mithulanathan, Multiple Distributed Generator Placement in Primary Distribution Networks for Loss Reduction *IEEE Transactions on Industrial Electronics*, Vol. 60, NO. 4, April 2013, pp. 1700-1708