

Cooling and heating loads in residential buildings in Kuwait

Eng. Essa S. Ben-Essa

Mechanical Engineering Department Section Head, PAAET, CTI, Kuwait

ABSTRACT: The aim of this paper is to estimate cooling load calculations, and will be presented for a one story villa with a basement, which is located in Kuwait (Adan), under Kuwait's design conditions at 3:00 Pm solar time. Design conditions were based on ASHRAE's fundamental books[1]. For each room, or area in the house, total conduction, solar radiation and internal thermal energies either it is sensible or latent have been calculated, conduction heat transfer occur in walls, glasses, doors, partitions and ceiling, where the solar heat transfer occur in glasses, however, the internal loads occur due to many reasons such as, people, lights and equipment, the total cooling load for solar, conduction and internal loads summed up to yield the total energy gained by the villa from these total energy gained the requirement air conditioning capacity is founded.

Keywords: Cooling energy savings, Indoor temperature, outdoor temperature, Residential Sector, solar radiation

Date of Submission: 03-05-2018

Date of acceptance: 09-06-2018

I. INTRODUCTION:

Energy Consumption is one of the most important issues in our life. Energy is used widely in many sectors, one of these sectors is the residential sector and the energy in this sector is used for different sources. Currently, the world is moving towards reducing the energy consumption as well as improving the energy efficiency of the building. This expansion will be very cost effective or maybe even free or at negative costs when implemented at research and this will be achieved by applying the energy evaluation requirements for the residential buildings. Kuwait is considered one of the richest countries in the petrol energy sources, but because of the economics changing and the price of petrol drop down where most of the countries searching for the renewable energy, This makes the search for clean, sustainable, and cheap energy sources a serious need also for Kuwait. Another objective of engineers and researchers is to find the optimum way of energy utilization in terms of production and efficiency.

Therefore, in this research the author is trying calculating the heat loss, Heat loss calculations are made to determine a building heating load. Under the fairly static conditions experienced under the assumptions used to make such calculations, Heat loss at and a heating load are functionally identical. Heat loss (the simultaneous summation of all heat flows out of a building) is synonymous with heating load (the capacity of equipment required to account for such a load). The same is not true of a heat gain and a cooling load.

Heat gain is a simultaneous summation of all heat flows into a building along with those flows generated inside the building. Cooling load is the

capacity of equipment required to account for such a load. Due to the dynamic nature of heat gain and the opportunities for heat storage (capacitance) that accompany dynamic loads, heat gain is often not equal to cooling load. Gains that enter a building but are stored in materials or furnishings do not have to be handled at that time and are not included in cooling load. In general, convective and latent heat flows are instantaneous, flow equals load. Radiant loads tend to be partially stored in a building (what percentage depends upon a number of factors), flow does not equal load.

As with heat loss, it is necessary to calculate a design load to characterize building performance during over-heated period (normally summer) conditions. Design cooling load calculations are normally made to size HVAC (heating, ventilating, and air-conditioning) systems and their components[2]. A building experiences a range of cooling loads in any given year, ranging in magnitude from zero (no cooling required) to whatever the maximum load happens to be that year. A design cooling load is a load near the maximum magnitude, but is not normally the maximum. This should become clear when the assumptions behind the calculations are understood. Design cooling load is intended to summarize all the cooling loads experienced by a building under a specific set of assumed conditions.

The assumptions behind design cooling load are as follows:

1. Weather conditions are selected from a long-term statistical database. The conditions will not necessarily represent any actual year, but are representative of the location of the building. ASHRAE has tabulated such data, as have other groups[1]. The designer may

select a severity of weather that seems appropriate for the building type in question although energy codes often specify what data shall be used (to minimize over-sized systems).

2. The solar loads on the building are assumed to be those that would occur on a clear day in the month chosen for the calculations.
3. The building occupancy is assumed to be at full design capacity.
4. All building equipment and appliances are considered to be operating at a reasonably representative capacity.
5. Lights are assumed to be operating as expected for a typical day of design occupancy.
6. Latent as well as sensible loads are considered.
7. Heat flow is analyzed assuming dynamic conditions, which means that heat storage in building envelope and interior materials is considered.

The above assumptions make calculation of design cooling load much more complicated and complex than calculations of design heat loss (with its many simplifying assumptions). Unfortunately, there is no way around this especially in a cooling load dominant climate as occurs in much of the southern United States.

The total building cooling load will involve heat transferred through the building envelope and heat generated by occupants, equipment, and lights. The envelope heat flows are termed external loads, in that they originate with the external environment. The other loads are termed internal loads, in that they

are generated from within the building itself. The percentage of external versus internal load varies with building type, site climate, and building design decisions. The total building cooling load also consists of sensible load components and latent load components. The sensible loads will affect dry bulb air temperature; the latent loads will affect absolute (and relative) humidity.

Buildings are classified as envelope-load-dominated and interior-load-dominated. Envelope-dominated buildings (also called external-load-dominated) experience the majority of their cooling loads as a result of the interaction between the exterior environment and the interior environment. Interior (or internal) load-dominated buildings experience the majority of their cooling loads as a result of activities occurring within the building. It is useful to be able to predict whether a building will be dominated by internal or external loads as this information should substantially change the focus of design efforts related to energy efficiency.

II. OBJECTIVES:

1. To determine cooling load of a residential building.
2. To learn how to master the cooling load calculations.

III. BASEMENT CALCULATIONS:

3.1 Total cooling load for below- grade room:

External LOADS	Conduction	Item	Orientation	Area, ft ²	U, Btu/hr.ft ² .F	CLTD, °F		Total Cooling, Btu/hr
		Wall	E	131.81	0.107	43.15	608.5734	
Wall	N	199.06	0.107	28.15	599.5787			
Glass	E	27.438	0.65	32.15	573.3856			
Partition (wall)	-	119.436	0.2	Δt	19	453.8568		
Partition (wall)	-	39.812	0.2	Δt	0	0		
Partition (wall)	-	147.3044	0.2	Δt	0	0		
Partition (wall)	-	19.906	0.2	Δt	0	0		
Partition (door)	-	21.52	0.57	Δt	0	0		
Total Conduction								2235.395
Solar	Item	Orientation	Area, ft ²	SC	Max SHG	CLF	Total Cooling, Btu/hr	
	Glass (shaded)	N	27.438	0.73	45	0.2	180.27	
Total Solar								180.27
Internal Loads	Item	N	HG	CLF	Load Limit	Total Cooling, Btu/hr		
	People							
	Sensible	5	710	1		3550		
	Latent	5	1090	1		5450		
	Lights	12	1964.16	1		1964.16		
	Equipments							
	TV	1	256	0.83		212.48		
	Receiver	1	102.4	0.83		84.992		
	DVD	1	61.43	0.56		34.4008		
	Ventilation	N	Q, cfm/person	Δt, °F	ΔW			
Sensible	5	15	39.8	-	3283.5			
Latent	5	15	-	0.01	3630			
Total Internal Load								18209.53
TOTAL LOAD								20625.195


3.2 Total cooling load for Below- grade living room:

External LOADS	Conduction	Item	Orientation	Area, ft ²	U, Btu/hr.ft ² .F	CLTD, °F	Total Cooling, Btu/hr	
		Wall	N	495.6594	0.107	28.15	1492.951	
Wall	W	513.3488	0.107	33.15	1820.874			
Wall	S	756.428	0.107	33.15	2683.088			
Wall	E	119.436	0.107	43.15	551.442			
Wall	E	27.8684	0.107	43.15	128.6698			
Wall	N	73.6522	0.107	28.15	221.8441			
Wall	E	29.59	0.107	43.15	136.6185			
Glass	S	11.9436	0.65	32.15	249.5914			
Glass	W	11.9436	0.65	32.15	249.5914			
Glass	S	11.9436	0.65	32.15	249.5914			
Glass	W	11.9436	0.65	32.15	249.5914			
Below grade	-	189.376	0.0489	Δt	19	176		
Partition (wall)	-	2868.186	0.2	Δt	0	0		
Door	-	1743.981	0.6	Δt	19	19881.38		
Floor	-	19.906	0.145	Δt	19	54.84		
Partition (wall)	-	19.906	0.2	Δt	0	0		
Partition (wall)	-	93.5582	0.2	Δt	0	0		
Partition (wall)	-	39.812	0.2	Δt	0	0		
Partition (wall)	-	119.436	0.2	Δt	19	453.8568		
Partition (wall)	-	18.292	0.2	Δt	0	0		
Partition (door)	-	17.216	0.57	Δt	19	186.4493		
Total Conduction							28852.94	
External LOADS	Solar	Item	Orientation	Area, ft ²	SC	Max SHG	CLF	Total Cooling, Btu/hr
		Glass (shaded)	N	11.9436	0.73	45	0.4	156.94
Glass (sunlit)	W	7.76	0.73	215	0.53	645.504		
Glass (shaded)	N	4.18	0.73	45	0.2	27.46		
Glass (shaded)	N	5.3	0.73	45	0.2	34.82		
Glass (shaded)	N	11.9436	0.73	45	0.4	156.94		
Glass (sunlit)	W	9.833	0.73	215	0.53	817.94		
Total Solar							1839.604	
Internal Loads	Item	N	HG	CLF	Load Limit	Total Cooling, Btu/hr		
	People							
	Sensible	15	710	1		10650		
	Latent	15	1090	1		16350		
	Lights	44	7201.92	1		7201.92		
	Equipments							
	TV	1	256	0.83		212.48		
	Receiver	1	102.4	0.83		84.992		
	DVD	1	61.43	0.56		34.4008		
	Ventilation	N	Q, cfm/person	Δt, °F	ΔW			
Sensible	15	15	39.8	-	9850.5			
Latent	15	15	-	0.01	10890			
Total Internal Load						55274.29		
TOTAL LOAD						85966.834		

3.3 Total Cooling Load for Basement:

Item	Cooling Load (Btu/hr)
Room	20,625.195
Living Room	85,966.834
Total	106,592.03
Total Cooling Load in tons	8.88

Figure 1: Basement



IV. GROUND FLOOR CALCULATIONS:

4.1 Living Room:

External LOADS	Conduction						
	Item	Orientation	Area, m ²	U, Btu/hr.ff.F	CLTD, °F	Total Cooling, Btu/hr	
External LOADS	Wall 1,2,4,6,7,10,11W,P1door	E	25.952	0.107	28.15	841.095444	
	Wall 3,11W,11,4W,12,13b,15,16,18,P2door	S	31.102	0.107	33.15	1187.04696	
	Wall 5,17	N	44.474	0.107	28.15	1441.38713	
	Wall 14	SE	13.394	0.107	40.15	619.14432	
	Wall 14	SW	5.143	0.107	33.15	196.289065	
	Wall	NE	8.436	0.107	37.15	360.820695	
	Glass 1	E	3.043	0.65	32.15	684.240155	
	Glass 2	E	3.9201	0.65	32.15	881.462318	
	Glass 3	S	3.9201	0.65	32.15	881.462318	
	Glass 4	N	3.18	0.65	32.15	715.045578	
	Partition 1,2 (doors)	-	11.0644	0.6	Δt 19	1357.20356	
	Partition (Wall) p2,p3,p4,p5	-	25.53	0.2	Δt 0	0	
	Partition (Wall) P6,p7	-	10.693	0.2	Δt 19	437.215384	
	Partition 3 (Bathroom door)	-	1.8	0.57	Δt 19	209.75544	
	Partition 5 (Bathroom door)	-	1.8	0.57	Δt 19	209.75544	
	Ceiling	-	152.96	0.078	Δt 0	0	
	Floor	-	152.96	0.078	Δt 0	0	
	Total Conduction						10021.924
	Solar	Item	Orientation	Area, m ²	SC	Max SHG	CLF
		Glass 1 (shade)	N	3.043	0.73	45	0.20
Glass 2 (shade)		N	3.9201	0.73	45	0.20	
Glass 3 (shade)		N	3.9201	0.73	45	0.20	
Glass 4 (shade)		N	3.18	0.73	45	0.20	
Total Solar						994.17261	
Internal loads	Item	N	HG	CLF	Load Limit		
	People						
	Sensible	30	245	1		7350	
	Latent	30	155	1		4650	
	Lights	75	12276	1		12276	
	Ventilation	N	Q, cfm/person	Δt, °F	ΔW		
	Sensible	30	15	39.8	-	19701	
	Latent	30	15	-	0.01	21780	
Total Internal Load						65757	
TOTAL LOAD						76773.1	

4.2 Room:

E	V	C	Item	Orientation	Area, m ²	U, Btu/hr.ft ² .F	CLTD, °F		Total Cooling, Btu/hr	
							Δt	0		
External LOADS	Conduction	Wall (W1)	W	2.7029	0.107	33.15			103.159579	
		Wall (W2)	S	2.7029	0.107	33.15			103.159579	
		Wall b	S	9.916	0.107	33.15			378.456614	
		Glass 1	W	3.9201	0.650	32.15			881.462318	
		Glass 2	S	3.9201	0.650	32.15			881.462318	
		Partition 1 (doors)	-	1.8	0.570	Δt	0		0	
		Partition (Wall)	-	16.65	0.200	Δt	0		0	
		Partition (Wall)	-	6.845	0.200	Δt	19		279.87836	
		Partition (Wall)	-	4.44		Δt	0		0	
		Ceiling	-	20.25	0.078	Δt	0		0	
		Floor	-	20.25	0.078	Δt	0		0	
		Total Conduction								3006.03538
		Solar	Item	Orientation	Area, m ²	SC	Max SHG	CLF		
			Glass 1 (shade)	N	3.9201	0.73	45	0.20		277.124413
Glass 2 (shade)	N		(0.13)3.9201	0.73	45	0.20		27.7124413		
Glass 2 (sunlit)	W		(0.9)3.9201	0.73	215	0.53		3157.83269		
Total Solar								3462.66954		
Internal loads	Item		N	HG		CLF				
	People									
	Sensible	6	245	1			1470			
	Latent	6	155	1			930			
	Lights	10	1636.8	1			8184			
	Appliances									
	TV	1	256	0.83			212.48			
	Receiver	1	102.4	0.83			84.992			
	Ventilation	N	Q, cfm/person	Δt, °F	ΔW					
	Sensible	6	15	39.8	-		3940.2			
Latent	6	15	-	0.01		4356				
Total Internal Load								8296.2		
TOTAL LOAD								14764.9		

4.3 Kitchen:

E	V	C	Item	Orientation	Area, m ²	U, Btu/hr.ft ² .F	CLTD, °F		Total Cooling, Btu/hr	
							Δt	0		
External LOADS	Conduction	Wall a	W	11.026	0.107	33.15			420.821161	
		Wall b	W	3.58	0.107	33.15			136.635204	
		Glass	W	3.043	0.650	32.15			684.240153	
		Wall c	W	1.11	0.107	33.15			42.3645464	
		Partition 4	-	11.47	0.2	Δt	0		0	
		Partition 8	-	4.07	0.2	Δt	0		0	
		Partition 9,10,11,12,15	-	37.444	0.2	Δt	0		0	
		Partition (door)	-	1.8	0.57	Δt	0		0	
		Partition 13	-	11.026	0.2	Δt	19		450.831088	
		Partition 14	-	8.066	0.2	Δt	0		0	
		Partition (door)	-	1.8	0.57	Δt	19		209.75544	
		Partition 16	-	12.95	0.2	Δt	19		529.4996	
		Ceiling	-	59.375	0.078	Δt	0		0	
		Floor	-	59.375	0.078	Δt	0		0	
		Total Conduction								2474.14719
		Solar	Item	Orientation	Area, m ²	SC	Max SHG	CLF		
			Glass (sunlit)	W	(0.75)3.043	0.73	215	0.53		2042.73804
			Glass (shade)	N	(0.25)3.043	0.73	45	0.20		53.7798519
Total Solar								2096.518		
Internal loads	Item		N	HG		CLF				
	People									
	Sensible	10	245	1			2450			
	Latent	10	155	1			1550			
	Lights	20	3273.6	1			3273.6			
	Appliances									
	Refrigerator									
	Sensible	-	300	1			300			
	Latent	-	0	1						
	Freezer									
	Sensible	-	1840	1			1840			
	Latent	-	0	1						
	Microwave									
	Sensible	-	8970	0.64			5740.8			
Latent	-	0	0.64			0				
Gas Oven										
Hooded	-	250	0.71			177.5				
Ventilation	N	Q, cfm/person	Δt, °F	ΔW						
Sensible	10	15	39.8	-		6567				
Latent	10	15	-	0.01		7260				
Total Internal Load								29158.9		
TOTAL LOAD								33729.57		

V. FIRST FLOOR CALCULATIONS:

5.1 Total cooling load for Room1

		Item	Orientation	Area, ft ²	U, Btu/hr.ft ² .F	CLTD, °F	Total Cooling, Btu/hr	
		External LOADS	Conduction	Wall	E	140.8	0.107	43.15
Wall	N			132.76	0.107	28.15	399.88	
Partition	-			201.152	0.2	ΔT=19	764.377	
Partition	-			60.34	0.2	ΔT=19	229.292	
Partition	-			28.161	0.2	ΔT=0	0	
Partition	-			80.461	0.2	ΔT=0	0	
Partition	-			48.276	0.2	ΔT=0	0	
Partition	-			48.276	0.2	ΔT=0	0	
Glass	E			34.3	0.65	215	4793.425	
Glass	N			22.867	0.65	45	668.86	
Glass	E			22.867	0.65	32.15	477.86	
Door	-			21.174	0.57	ΔT=0	0	
Door	-			21.174	0.57	ΔT=19	229.31	
Ceiling	-			415.3	0.078	43.15	1397.77	
Total Conduction							9610.854	
External LOADS	Solar	Item	Orientation	Area, ft ²	SC	Max SHG	CLF	
		Glass (Shade)	N	22.867	0.73	45	0.20	150.2362
		Glass(Shade)	N	22.867	0.73	45	0.20	150.23
		Glass(Shade)	N	40.23	0.73	45	0.20	264.3111
		Total Solar						
Internal loads	Item	N	HG	CLF	Load Limit			
	People							
	Sensible	3	245	1		735		
	Latent	3	155	1		465		
	Lights	25	4092	1		4092		
	Equipment							
	TV	1	256	0.83		212.48		
	Receiver	1	102.4	0.83		84.992		
	DVD Player	1	61.43	0.56		34.4		
	Ventilation	N	Q, cfm	Δt, °F	ΔW			
	Sensible	3	15	39.8	-	1970.1		
	Latent	3	15	-	0.01	2178		
	Total Internal Load							9771.972
TOTAL LOAD							19947.61	

5.2 Total cooling load for Room2

External LOADS	Item	Orientation	Area, ft ²	U, Btu/hr.ft ² .F	CLTD, °F	Total Cooling, Btu/hr	
Conduction	Wall	S	189.08	0.107	33.15	670.67	
	Wall	W	160.922	0.107	33.15	570.79	
	Partition	-	100.57	0.2	ΔT=19	382.16	
	Partition	-	40.23	0.2	ΔT=19	152.87	
	Glass	W	34.301	0.65	32.15	716.8	
	Glass	S	34.301	0.65	32.15	716.8	
	Door	-	21.17	0.57	ΔT=0	0	
	Door	-	21.17	0.57	ΔT=19	229.27	
	Ceiling	-	224.884	0.078	43.15	756.87	
Total Conduction						4196.288	
Solar	Item	Orientation	Area, ft ²	SC	Max SHG	CLF	Total Cooling, Btu/hr
	Glass (shade)	N	22.867	0.73	45	0.20	150.24
	Glass (shade)	N	22.867	0.73	45	0.20	150.24
Total Solar						300.47238	
Internal loads	Item	N	HG	CLF	Load Limit	Total Cooling, Btu/hr	
	People						
	Sensible	3	245	1		735	
	Latent	3	155	1		465	
	Lights	20	3264	1		3264	
	Equipments						
	TV	1	256	0.83		212.48	
	DVD Player	1	61.43	0.56		34.4	
	Receiver	1	102.4	0.83		84.99	
	Ventilation	N	Q, cfm	Δt, °F	ΔW		
Sensible	3	15	39.8	-	1970.1		
Latent	3	15	-	0.01	2178		
Total Internal Load						8943.97	
TOTAL LOAD						13440.7304	

5.3 Total cooling load for Room3

External LOADS	Item	Orientation	Area, ft ²	U, Btu/hr.ft ² .F	CLTD, °F	Total Cooling, Btu/hr	
Conduction	Partition	-	100.576	0.2	ΔT=19	382.1888	
	Partition	-	120.69	0.2	ΔT=19	458.622	
	Wall	S	160.92	0.107	33.15	570.79	
	Wall	W	120.67	0.107	33.15	428.022	
	Glass	W	34.301	0.65	32.15	716.8	
	Glass	S	34.301	0.65	32.15	716.8	
	Door	-	16.939	0.57	ΔT=19	183.449	
	Door	-	21.17	0.57	ΔT=0	0	
	Ceiling	-	330.81	0.078	43.15	1113.4	
Total Conduction						4570.09	
Solar	Item	Orientation	Area, ft ²	SC	Max SHG	CLF	Total Cooling, Btu/hr
	Glass	S	34.3	0.73	98.5	0.94	2318.36101
	Glass	N	34.3(0.1)	0.73	45	0.20	22.5351
Glass	W	34.3(0.9)	0.73	215	0.53	2567.87465	
Total Solar						5171.555	
Internal loads	Item	N	HG	CLF	Load Limit	Total Cooling, Btu/hr	
	People						
	Sensible	3	245	1		735	
	Latent	3	155	1		465	
	Lights	10	1636.8	1		1636.8	
	Equipments						
	TV	1	256	0.83		212.48	
	DVD Player	1	61.43	0.56		34.4	
	Receiver	1	102.4	0.83		84.992	
	Ventilation	N	Q, cfm	Δt, °F	ΔW		
Sensible	3	15	39.8	-	1970.1		
Latent	3	15	-	0.01	2178		
Total Internal Load						7316.772	
TOTAL LOAD						16795.63	

5.4 Total cooling load for Room4

External LOADS	Item	Orientation	Area, ft ²	U, Btu/hr.ft ² .F	CLTD, °F	Total Cooling, Btu/hr
Conduction	Partition	-	100.576	0.2	ΔT=19	382.188
	Partition	-	104.6	0.2	ΔT=19	397.48
	Wall	N	112.645	0.107	28.15	339.3
	Wall	W	144.83	0.107	33.15	513.72
	Glass	N	34.301	0.65	32.15	716.8
	Glass	W	34.301	0.65	32.15	716.8
	Door	-	21.17	0.57	ΔT=0	0
	Ceiling	-	258.64	0.078	43.15	870.5
Total Conduction						3936.7926
Solar	Item	Orientation	Area, ft ²	SC	Max SHG	CLF
	Glass	N	34.3	0.73	45	0.20
	Glass (shade)	N	34.3(0.1)	0.73	45	0.20
	Glass (sunlit)	W	34.3(0.9)	0.73	215	0.53
Total Solar						3078.541
Internal loads	Item	N		HG	CLF	Load Limit
	People					
	Sensible	3		245	1	735
	Latent	3		155	1	465
	Lights	10		1636.8	1	1636.8
	Equipments					
	TV	1		256	0.83	212.48
	DVD Player	1		61.43	0.56	34.4
	Receiver	1		102.4	0.83	84.992
	Ventilation	N		Q, cfm	Δt, °F	ΔW
Sensible	3		15	39.8	-	
Latent	3		15	-	0.01	
Total Internal Load						7316.772
TOTAL LOAD						14069.3207

5.5 Total cooling load for Room5

External LOADS	Item	Orientation	Area, ft ²	U, Btu/hr.ft ² .F	CLTD, °F	Total Cooling, Btu/hr
Conduction	Partition	-	108.622	0.2	ΔT=19	412.7636
	Partition	-	80.461	0.2	ΔT=19	305.75
	Wall	N	96.55	0.107	28.15	290.8134
	Glass	N	34.301	0.65	32.15	716.8
	Door	-	21.17	0.57	ΔT=0	0
	Ceiling	-	177.26	0.078	43.15	596.6
	Total Conduction					
Solar	Item	Orientation	Area, ft ²	SC	Max SHG	CLF
	Glass	N	34.3	0.73	45	0.2
Total Solar						225.351
Internal loads	Item	N		HG	CLF	Load Limit
	People					
	Sensible	3		245	1	735
	Latent	3		155	1	465
	Lights	10		1636.8	1	1636.8
	Equipments					
	TV	1		256	0.83	212.48
	DVD Player	1		61.43	0.56	34.4
	Receiver	1		102.4	0.83	84.99
	Printer	1		1500	0.56	840
Mini-Computer	1		1000	0.82	820	
Ventilation	N		Q, cfm	Δt, °F	ΔW	
Sensible	3		15	39.8	-	
Latent	3		15	-	0.01	
Total Internal Load						8976.77
TOTAL LOAD						11524.85

5.6 Total cooling load for living room

External Loads	Conduction					
	Item	Orientation	Area, ft ²	U, Btu/hr.ft ² .F	CLTD, F	Total Cooling, Btu/hr
Solar	Partition	-	120.69	0.2	ΔT=19	458.622
	Partition	-	52.3	0.2	ΔT=19	198.47
	Wall	SW	56.86	0.107	33.15	201.68
	Wall	SE	56.86	0.107	40.15	244.273
	Glass	S	21.173	0.65	32.15	442.46
	Glass	S	21.173	0.65	32.15	442.46
	Glass	S	21.173	0.65	32.15	442.46
	Glass	S	21.173	0.65	32.15	442.46
	Ceiling	-	815.932	0.078	43.15	2746.18
	Total Conduction					
Internal loads	Item	Orientation	Area, ft ²	SC	Max SHG	CLF
	Glass	N	21.173	0.73	45	0.20
	Glass	N	21.173	0.73	45	0.20
	Glass	N	21.173	0.73	45	0.20
	Glass	N	21.173	0.73	45	0.20
Total Solar						556.42644
Internal loads	Item	N	HG	CLF	Load Limit	
	People					
	Sensible	7	245	1		1715
	Latent	7	155	1		1085
	Lights	60	9792	1		9792
	Equipments					
	TV	1	256	0.83		212.48
	DVD Player	1	61.43	0.56		34.4
	Receiver	1	102.4	0.83		84.99
	Mini-Computer	1	1000	0.82		820
Ventilation	N	Q, cfm	Δt, °F	ΔW		
Sensible	7	15	39.8	-	4596.9	
Latent	7	15	-	0.01	5082	
Total Internal Load						13743.87
TOTAL LOAD						25087.335

VI. TOTAL COOLING LOAD:

Floor	Cooling Load (Btu/hr)
Basement	106,592.03
Ground	125,267.57
First	100,865.476
Total Cooling Load	332,725.08
Total Cooling Load in tons	27.73

VII. SAMPLE CALCULATIONS:

7.1 Design Conditions (summer):

- Outdoor Design condition : 115°F (DB) , 69°F (WB) , 28% (RH) , 0.0173w
- Indoor Design condition : 76°F (DB) , 62°F (WB) , 50% (RH) , 0.0093 (w)
- Daily Range : 27.7°F
- Ground Temperature : 35°C
- Latitude : 29.5° North
- Solar Time : 15:00 hr
- July 21st

7.2 ExternalParameters:

7.2.1 Roof:

Assume 4 in. wood with 2 in. insulation
 U = 0.078 Btu/hr.ft².°F (Table28)
 CLTD = 24°F (Table 29), with suspended ceiling
 $CLTD_{corr} = [(CLTD + LM)K + (78 - t_R) + (t_o - 85)]f$

LM = 1 (table 32)
 f = 1 (ducts)
 K = 1 (Dark colored area)
 t_o = 115 - 27.7/2 = 101.15°F

CLTD_{corr} = 43.15° F


7.2.2 Wall:

Assume Group B (4 in Face Brick + 2 in. insulation + 8 in concrete block) → Table 30

→ U = 0.107Btu/hr.ft².°F
 $CLTD_{corr} = [(CLTD + LM)K + (78 - t_R) + (t_o - 85)]$

5.7 Total Cooling Load in First Floor:

Item	Cooling Load (Btu/hr)
Room 1	19,947.61
Room 2	13,440.7304
Room 3	16,795.63
Room 4	14,069.3207
Room 5	11,524.85
Living Room	25,087.335
Total Cooling Load	100,865.476
Total Cooling Load in tons	8.41



Orientation	CLTD values From Table 31 (°F)	Corrected CLTD (°F)
North	9	28.15
East	24	43.15
South	14	33.15
West	14	33.15
South-East	21	40.15
South-West	14	33.15
North-East	18	37.15

- Below-Grade:

From table 5.9 at depth 3.2 m, using extrapolation
 $\rightarrow U = 0.0489 \text{ Btu/hr.ft}^2.\text{°F}$

• **Basement Floor:**

From table 5.9 at depth 3.2 m, using extrapolation
 $\rightarrow U = 0.145 \text{ Btu/hr.ft}^2.\text{°F}$

• **Partition (Wall):**

Assume (4 in Heavy weight concrete + 2 in. insulation) Group D
 $\rightarrow U = 0.200 \text{ Btu/hr.ft}^2.\text{°F}$

• **Partition (Door):**

➤ **Outside Doors :** assume 1 3/4 steel door + fiberglass without thermal break

$\rightarrow U = 0.6 \text{ Btu/hr.ft}^2.\text{°F}$ (table 5.8)

➤ **Inside Doors :** assume wood 1 3/8 solid core flush door

$\rightarrow U = 0.57 \text{ Btu/hr.ft}^2.\text{°F}$ (table 5.8)

7.2.3 Windows:

➤ Assume double glazing ,Aluminum with thermal break, 1/4 in. air space $\rightarrow U$ from table 5-5a $0.65 \text{ Btu/hr.ft}^2.\text{°F}$

➤ CLTD from table 33 is 14° F $\rightarrow \text{CLTD}_{\text{corr}} = 32.15^\circ \text{ F}$

➤ **Max. SHGF:**

Orientation	Max. SHGF values From Table 34 (Btu/hr.ft ²)
North	45
East	215
South	98.5
West	215

➤ **CLF :Assume Uncarpeted Floors**

Orientation	CLF values From Table 38
North	0.2
East	0.21
South	0.94
West	0.53

➤ $SC = 0.73$ (Assume open wave fabric and medium colored)

From figure 7.12 $\rightarrow I_m \rightarrow$ between C and D
 Table 7.5 \rightarrow Choose (C), insulating glass 1/4 in. air space $\rightarrow SC = 0.73$

7.3 Internal Parameters:

8.3.1 Lights:

CLF = 1 (24 hr operation)

W = 40 watts, $F_{ul} = 1$ (24 hr operation) , $F_{sa} = 1.2$

7.3.2 People :

Table 3 for seated, very light work

$(\text{HG})_{\text{sensible}} = 245 \text{ Btu/hr}$, $(\text{HG})_{\text{latent}} = 155 \text{ Btu/hr}$
 CLF = 1 (24 hr operation)

7.3.3 Equipments:

➤ **Kitchen: unhooded ,table 8**

Refrigerator: $(\text{HG})_{\text{sensible}} = 300 \text{ Btu/hr}$, $(\text{HG})_{\text{latent}} = 0 \text{ Btu/hr}$

Microwave : $(\text{HG})_{\text{sensible}} = 8,970 \text{ Btu/hr}$, $(\text{HG})_{\text{latent}} = 0 \text{ Btu/hr}$

Freezer: $(\text{HG})_{\text{sensible}} = 1,840 \text{ Btu/hr}$, $(\text{HG})_{\text{latent}} = 0 \text{ Btu/hr}$

Gas Oven: $(\text{HG})_{\text{hooded}} = 250 \text{ Btu/hr}$

CLF values: table 48

Refrigerator: CLF = 1 (24 hr Operation)

Microwave : CLF = 0.64 (2 hr operation and from 2:00 PM to 3:00 PM)

Freezer: CLF = 1 (24 hr Operation)

Gas Oven: CLF = 0.71 (9:00 AM to 5:00 PM)

➤ **Room: table 9**

Mini-Computer: HG = 1000 Btu/hr

Printer: HG = 1500 Btu/hr

CLF Values: table 48

Mini-Computer: CLF = 0.82 (10 hr operation, from 10:00 AM to 10:00 PM)

Printer: CLF = 0.56 (2 hr operation time, from 2:00 PM to 3:00 PM)

➤ **External Data: (internet or manual work)**

TV: $\text{HG} = 75 \text{ W} = 3.4129 \times 75 = 256 \text{ Btu/hr}$

Receiver: $\text{HG} = 30 \text{ W} = 102.4 \text{ Btu/hr}$

DVD Player: $\text{HG} = 18 \text{ W} = 61.43 \text{ Btu/hr}$

CLF Values: table 48

For TV and receiver CLF = 0.83 (from 9:00 AM to 11:00 PM)

For DVD player CLF = 0.56 (from 2:00 PM to 4:00 PM)

7.4 Ventilation:

$Q = 15 \text{ [CFM/Person]} \times N$

$\Delta W = 0.01$, $\Delta t = 39.8^\circ \text{ F}$

$q_{\text{latent}} = 4840 Q \Delta W$, $q_{\text{sensible}} = 1.1 Q \Delta t$

VIII. DISCUSSION & CONCLUSION

The results of the energy simulation for the house model and the enhanced scenarios are illustrated and discussed.

1. Total cooling load was evaluated to be 27.73 tons for a 380 m² villa using CLTD method.
2. The cooling load for the first floor is 8.4 tons, 10.4 tons for ground floor and 8.9 tons for the basement.

3. The smallness of this value may be due to totally shading on most of the windows and/or because of draperies or internally shading.
4. The ground floor has the maximum cooling load, and account for nearly 37.5% of the total cooling load that is due high internal loads.
5. The ground floor requires the maximum amount of cooling while the first floor and the basement require the minimum amount of cooling.
6. The orientation of each wall and glass takes an important rule to calculate the cooling load.
7. The wall, which means the wall that separate the outside environment from inside condition at the home has higher insulation material than the partition which is used between two rooms in the floor.
8. The wall must have high insulation material than the partition because it expose to humidity, water, dust and solar radiation.
9. Very small areas compared with others may be ignored if found to have minute influence.
10. As A.C. engineers we should be able to calculate the cooling load required for a space, to determine the satisfactory HVAC System.
11. Internal and external shading play an important role in the cooling load reduction.
12. Windows facing south, east and north are totally shaded while windows facing west have 10-35% shading depending on the floor.
13. For a totally shaded glass a north orientation is used in our calculations.
14. The largest CLTD factor for the wall appears at east orientation so that the wall facing east has the largest conduction (CLTD=43.15).
15. The maximum solar heat gain factor for the windows appear at east and west ordinations (SHGF=215).

IX. PICTURES:



Picture 1: totally shaded for windows facing south.



Picture 2: totally shaded for windows facing east.




Picture 3: 25% shaded window facing west.



Picture 4: 10% shading for window facing west (Ground Floor).



Picture 7: totally shaded window facing east (Basement).



Picture 5: 10% shading for window facing west (First Floor).



Picture 8: 20% shading for window facing west (First Floor).



Picture 6: 35% shading for window facing west (Basement).

REFERENCES:

- [1]. Energy estimating and modeling methods, ASHRAE Handbook , American Society of Heating, Refrigerating, and Air-Conditioning Engineers, 2013, Atlanta-USA.
- [2]. Heating, Ventilation, and Air Conditioning, Analysis and design sixth edition byMcQuiston, Parker, and Spitler.

- [3]. Cooling and heating loads in residential buildings in Jordan, HasanJarad, Moh'd Sami and Ashhab, Volume 11 Number 1, January. 2017 ISSN 1995-6665 Pages 51 -59
- [4]. Energy Rating for Residential Buildings in Amman, B.R. Qawasmeha, A. Al Salaymeha, Ma'en S. Sarib, NadeenEliana andNadeenZahrana. Int. J. of Thermal & Environmental Engineering Volume 14, No. 2 (2017)109-118

S. Ben-Essa "Cooling and heating loads in residential buildings in Kuwait"
International Journal of Engineering Research and Applications (IJERA) , vol. 8, no.5,
2018, pp.01-14